

VERIFICATION OF CONFORMITY

No.: IN-XM-CP-5627-25133

Applicant: VICTOR BUILDING MATERIALS (HK) LIMITED

Address: FLAT 01, 28/F., ONE MIDTOWN, 11 HOI SHING ROAD, TSUEN WAN, N.T.

Manufacturer: Victor Sunrise Green Materials (Shandong) Limited

It has been verified that

Product(s): VICTOR GYPSUM BLOCK

Product material: Gypsum Block

Product Specification: VT80/VT100/VT150

are submitted by the applicant to the testing of the product in

accordance with ISO 16000-9:2024&ISO 16000-6:2021&ISO 16000-3:2022.

Based on the submitted sample(s), test was performed according to Decree 2011-321 relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is A+ class.

on basis of the test report of CANIN25020775701.

The French A+ example logo is as follows



This verification is valid from Sep 04, 2025 until Sep 03, 2028 and remains valid as long as the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

> Issue 1. Verified since Sep 04, 2025 Authorised by



Jeson Jin/

Jeson Jin

Senior Manager

Industries Service - CP Certification

SGS-CSTC Standards Technical Services Co. Ltd.

Century Yuhui Mansion No. 73, Fucheng Road, Haidian District, Beijing, China 100142

email CN.CONSTProdcert@sqs.com_website_www.sqs\com



Disclaimer: Neither SGS-CSTC, any of it affiliated SGS sister organizations nor the SGS Group can be held responsibly for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.

Page 1 of 2 IND-CCM-VOC-01



VERIFICATION OF CONFORMITY

No.: IN-XM-CP-5627-25133

··continued··

Results of examinations are as following:

				miduono		
Compound Name	CAS NO.	7 days result µg/m³	Classes requirements			
			С	В	Α	A+
Formaldehyde	50-00-0	Not detected	> 120	< 120	< 60	< 10
Acetaldehyde	75-07-0	Not detected	> 400	< 400	< 300	< 200
Toluene	108-88-3	3.4	> 600	< 600	< 450	< 300
Tetrachloroethylene	127-18-4	Not detected	> 500	< 500	< 350	< 250
Xylene	1330-20-7	7.0	> 400	< 400	< 300	< 200
1,2,4-	95-63-6	Not detected	> 2000	< 2000	< 1500	< 1000
Trimethylbenzene			1			
1,4-Dichlorobenzene	106-46-7	Not detected	> 120	< 120	< 90	< 60
Ethylbenzene	100-41-4	Not detected	> 1500	< 1500	< 1000	< 750
Ethylene Glycol	111-76-2	Not detected	> 2000	< 2000	< 1500	< 1000
Monobutylether						
Styrene	100-42-5	2.2	> 500	< 500	< 350	< 250
TVOC	1	127.5	> 2000	< 2000	< 1500	< 1000

Conclusion: Based on the submitted sample(s), test was performed according to Decree 2011-321 relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is A+ class.

Statement: Unless otherwise stated the results shown in this verification refer only to the sample(s) tested. The manufacturer is obligated to guarantee stability of product performance.

Issue 1. Verified since Sep 04, 2025 Authorised by

Jeson Jin/

Jeson Jin
Senior Manager
Industries Service - CP Certification